



January 22, 2019

RECEIVED

JAN 30 2019

Mr. Bryce Bird, Director
Utah Department of Environmental Quality
Division of Air Quality
195 North 1950 West
P.O. Box 144820
Salt Lake City, UT 84114-4820

Office of Enforcement Compliance
and Environmental Justice

And

Director, USEPA Region VIII
8 ENF-AT
1595 Wynkoop St.
Denver, CO 80202 - 1129

RE: **Huntington Unit 1 Boiler Performance Tune-Up, Notice of Completion, 40 CFR 63.10006(j),
Huntington Power Plant (Title V Permit #1501001004)**

Dear Mr. Bird:

*This reference
is incorrect.*

Huntington Power Plant is subject to the requirements of 40 CFR §63 Subpart UUUUU. Specifically, 40 CFR §63.10006(j) requires the source to report the results of performance tune-ups within 60 days after the completion of tune-up. This letter is sent to satisfy the reporting requirements of 40 CFR §63.10006(j).

Huntington Unit 1 completed the performance tune-up on December 11, 2018. At the conclusion of the optimization tune-up the unit controlled NOx and CO below permitted values over its operational range. The boiler optimization tune-up report is archived at the plant and is available upon request

I am authorized to make this submission on behalf of the owners and operators of the affected source or affected units for which the submission is made. I certify under penalty of law that I have personally examined, and am familiar with, the statements and information submitted in this document and all its attachments. Based on my inquiry of those individuals with primary responsibility for obtaining the information, I certify that the statements and information are to the best of my knowledge and belief true, accurate, and complete. I am aware that there are significant penalties for submitting false statements and information, or omitting statements and information, including the possibility of fine or imprisonment.

Should you have any questions regarding this information, please contact Russ Willson, Huntington Power Plant Sr. Environmental Analyst at (435) 687-4331 or me at (435) 687-4211.

Sincerely,

Darrell Cunningham
Managing Director Huntington Plant
Responsible Official